




**APPEX[®]
VALVES**

DOUBLE WINDOW SIGHT GLASS

SIZE	ØNB	F	Ø OD	FT	ØRf	ØPCD	Ød	N	ØV
15	13	130	88.9	9.65	34.9	60.3	15.8	4	40
20	19	150	98.4	10.4	42.9	69.8	15.8	4	48
25	25	160	108	11.1	50.8	79.2	15.8	4	48
40	38	200	127	14.2	73	98.5	15.8	4	65
50	50	230	152.4	15.8	92.1	120.6	19	4	75
65	63	290	177.8	17.5	104.7	139.7	19	4	100
80	75	310	190.5	19	127	152.4	19	4	250
100	100	350	228.6	23.8	157.2	190.5	19	8	150



P.NO	NOMENCLATURE	MATERIAL	QTY.
5	STUD & NUT	ASTM A 193 Gr. B7/B8 & 2H/8	4/8
4	GLASS	TOUGHEN	2
3	GASKET	PTFE	2
2	COVER	CF8M/CF3M/CF8/CF3/WCB	2
1	BODY	CF8M/CF3M/CF8/CF3/WCB	1

BILL OF MATERIAL

CONSTRUCTION:- CASTED CONSTRUCTION , DRIP TYPE , TOUGHENED GLASS DOUBLE WINDOW SIGHT GLASS	
DESIGN & MFG. CODE	ASME B 16.340
INSPECTION & TESTING	API 598
FACE TO FACE	SHOWN IN DRAWING
END CONNECTION	ASME B 16.5 Rf to ASA 150#
CLIENT	
P.O. NO.	

SHELL (BODY)	kg/cm ²	10	
	Psig	145	
SEAT	kg/cm ²	-	
	Psig	-	
	BAR	-	

HYDROSTATIC PRESSURE TESTING	10	-
	145	-
PNEUMATIC PRESSURE TESTING	-	-
	-	-

TYPE	RATING	NOMINAL SIZE	DESCRIPTION		MATERIAL
DOUBLE WINDOW	PN6 / PN10	AS SHOWN	ASSEMBLY DOUBLE WINDOW		AS SHOWN
SCALE	END CONNECTION	STANDARD	ALL DIMENSIONS ARE IN M.M. UNLESS OTHERWISE SPECIFIED		DESIGN
NTS	FLANGE END	MFG.	REMOVE SHARP CORNERS		KMS
PROJECTION	UNSPECIFIED TOLERANCES FOR MACHINED DIMENSIONS				CHECKED
	THIRD ANGLE	0-75	75-300	300-600	ABOVE 600
Appex	SHARVIL ENGINEERS				APPROVED
	147, ADARSH ESTATE, RAKHIAL, AHMEDABAD -380 023.				DATE
					REV.
				DRG. No.	00
				SE/DWS/15-100/150#	

FOR REFERENCE

FOR APPROVAL

FOR RECORD